



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI -110001

No. F6/DFS/MS/WZ/2023/ 16 |

Dated: 11 /07 /2023

To,

The Joint Commissioner of Police,
Licensing Unit, 1st floor, Police Station,
Defence Colony, New Delhi.
adlcp.lic-dl@nic.in

Subject: Issuance of Fire Safety Certificate in respect M/s. Kasso (A Unit of I.G Foods)
Located at Portion of Third Floor, Plot no.-30, Shivaji Marg, Najafgarh Road,
New Delhi- 110015.

Sir,

Please refer to the online application Id No. 2023062111283 dated 22/06/2023 received through MHA portal on the subject cited above. In this connection, it is to inform you that the premises was inspected by the officer concerned of this department on 03/07/2023 in the presence of Sh. Sanjeev to check the fire safety arrangements provided in the building.

During inspection, it was observed that the said restaurant is running at Third floor in a building comprised of Basement + Ground + 03 upper floors. The fire safety arrangements such as Fire Extinguishers, First-Aid Reels, Automatic Fire Detection and Alarming System, Public Address System etc are provided. However the following shortcomings were observed.

1. Fire Check Door is not provided
2. MOEFA is provided but not functional.
3. Terrace level pump capacity of 450 LPM is not provided.
4. Overhead water storage tank capacity of 10,000 ltr is not provided.
5. Exit Signage's are not provided.

In view of above Shortcomings, the application for issuance of Fire safety Certificate is not considered at this stage & rejected. The occupancy of the Building/ premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/occupier. The licensing issuing authority/statutory authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements.

Yours Faithfully,

(Atul Garg)
Director

Copy to: -

1. The Owner/Occupier M/s. Kasso (A Unit of I.G Foods) Located at shop no. Portion of Third Floor, Shivaji Marg, Najafgarh Road, New Delhi- 110015.
2. The Dy. Health Officer, West Zone, South Delhi Municipal Corporation, Shivaji Enclave, Raja Garden, New Delhi-110027. Email Id:- (dhowest_zone@gmail.com)

Atul Garg
07/07/2023