

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/MS/EH/2023/SZ/ 376

Dated 11 /07 /2023

To

The Dy. Health Officer, MCD,
Public Health Officer,
Aurobindo Marg,
Green Park, Delhi 110016

Sub: - Regarding issuance of fire safety certificate in r/o M/s Jubilant Foodworks (Dominos Pizza) located at Shop No C-7, Ground Floor, Opposite Malviya Nagar Market, New Delhi 110017.

Sir,

This has reference to your **MHA Portal ID. 2023060810514** dated **08/06/2023** on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 10.07.2023 in the presence of Ms. Sonal (Manager) to verify the fire safety measures installed in the building and observed that restaurant running at Ground floor only. During inspection, following points were observed:

- 1 There are two exits having width of 1 mtr each against the required exits width of 1.50 mtr each.
- 2 First Aid Hose reel hose not provided.
- 3 MOEFA not provided.
- 4 Internal Hydrants not provided.
- 5 Terrace level Fire Pump capacity of 450 LPM not provided.
- 6 Overhead tank capacity 20,000 ltrs not provided.
- 7 Exit signage not provided.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE