



75
Azadi Ka
Amrit Mahotsav

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

No. F.6/DFS/MS/EH/2023/NDZ/ 177

Dated: 13/07/2023

To,

Sh. Ankit Gumber
M/s Abhishek (Eating House),
Main Patparganj Road, Plot No. 16/123,
Shivpuri, Delhi-110051

Subject:- Regarding online application ID No. 2023061611055 in r/o M/s Abhishek Party Hall located at Main Patparganj Road, Plot No. 16/123, Shivpuri, Delhi-110051.

Sir,

With reference to your online MHA application No. 2023061611055 dated 20/06/2023 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department have carried out the inspection of premises from fire safety point of view in presence of Mr. Abhishek on dated 05/06/2023. The building comprised of ground plus three upper floors. Proposed eating house is on ground and first floor. Following shortcomings were observed during the time of inspection.

1. Two number of staircase width 1.5 meter not provided.
2. First Aid hose Reels provided but not functional.
3. Down-Comer provided but not functional.
4. Terrace pump of capacity 450 LPM with 60 meter head provided but not functional.
5. Auto starting pump not provided.
6. Overhead tank 10,000 liters provided against the requirement of 20,000 liters.
7. Exits signage not provided.

In view of above, the application for issuance Fire Safety Certificate is rejected. The occupancy of building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to:-

The Joint Commissioner (Lic.)

1st floor Police Station Defence Colony, New Delhi w.r.to MHA ID 2023061611055
dated 20/06/2023

ok R.