

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELH FIRE SERVICE
CONNAUGHT PLACE: NEW DELHI-110001

No. F.6/DFS/MS/Hotel/2023/SZ/ 379

Dated: 12/07/2023

To,

The Dy. Health Officer, (MCD)
Public Health officer, (Green Park Zone)
Aurobindo Marg, Green Park, Delhi-110016.

Sub:- Regarding Issuance of Fire Safety Certificate in r/o **M/S BEGUM A UNIT OF BEL CIBO HOSPITALITY PVT. LTD**, Located At Shop no D-5 Third Floor, Defense Colony, New Delhi-1100209

Sir,

This is in reference to with MHA Portal No.2023062911721 dated 30/06/2023 the subject cited above. In this connection, it is to inform you that the above mentioned premise was visited by the officer concerned of this department on 04/07/2023 in the presence of Mr. Sanjay to verify the fire safety measures installed on the building and observed that the restaurant running at 3rd floor only. During the inspection, the shortcomings observed are as below: -

1. The staircases are having width of 1.60mtr & 1.30mtr wide provided against the required width of 1.50mtr each.

The building is comprised of Basement, Ground Plus 03 upper floors, whereas the height mentioned in the above said MHA portal application is 14.90mtr and its seems to be wrong. In view of above, the management/ owner of the building may be please directed to submit height verification certificate & plans/section/elevation drawing of the building up to last occupied floor as Eating House, for further action in the matter in accordance with the provision contained in Delhi Fire Service Rules, 2010.

In view of above shortcomings, the application for issuance of Fire Safety Certificate is rejected. The occupancy of the building / premise in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours Faithfully,


(Director)
Delhi Fire Service
Dy. M

Copy to: -

1. The Executive Engineer, Building Department, MCD, (Green Park Zone) Aurobindo Marg, Green Park, Delhi-110016.