

c86

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SZ/2023/ college/35

Dated: 11/07/2023

To,

The Principal,
Kamal Education & Welfare Society
Trinity Institute of Professional Studies,
Sector – 09, Dwarka, New Delhi – 110075.

Subject: Renewal of Fire Safety Certificate in r/o Kamal Education & Welfare Society for Trinity Institute of Professional Studies, Located at Sector – 09, Dwarka, New Delhi – 110075.

Sir,

Please refer to your letter No. Nil dated 15/06/2023 on the subject mentioned above. In this connection it is to inform you that the premise was re-inspected by the team of officers from this department on 28/06/2023 in presence of Dr. Ashutosh Agarwal for fire safety point of view.

During the course of inspection following shortcomings were observed.


1. Internal road around the building found encroached.
2. Staircases found locked at terrace level.
3. Pressurization system provided in staircases found removed/ nonfunctional.
4. Some Exhaust system provided in basement found nonfunctional.
5. MOEFA found nonfunctional.
6. PA system found nonfunctional.
7. All fire pumps found nonfunctional except diesel pump and all the pumps must be kept functional in auto mode.
8. Main valve at terrace found closed.
9. Exit signage's found removed at some places.
10. Pressurization system in lift lobby found removed.
11. Communication in lift car found nonfunctional.
12. Lift lobby found removed in basement.
13. Refused area found not clear.

You are requested to comply the above mentioned shortcomings under intimation to this department.

In view of the above shortcomings Fire Safety Certificate cannot be considered at this stage.

Yours faithfully,


(Atul Gang)
Director

o/c
Delhi Fire Service


Copy to; - Directorate of Education Old Secretariat Delhi – 110054.