

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI - 110001**

DATED: 12/07/2023

NO. F6/DFS/MS/SZ/2023/Sch) 363

To,

The Principal,
Paramount International School,
Sector 23, Dwarka, New Delhi - 110075.

Subject: - Issuance of Fire safety Certificate from fire safety & means of escape point of view in r/o Paramount International School Located at Sector 23, Dwarka, New Delhi - 110075.

Sir,

Please refer to your Email Dated 17-06-2023 on the subject cited above. In this connection it is to inform to you that the above said building has been inspected by the officers concerned of this department on 07/07/2023 in presence of Sh. Saket (Owner) for fire safety point of view.

During the course of inspection followings shortcoming have been observed:-

1. Six m internal road around the building found not provided.
2. Fire Check Doors found not provided.
3. MOEFA found not extended in some areas.
4. Hose reel & hydrants found nonfunctional.
5. Public address system not extended to 4th floor.
6. Exit signage found not provided.
7. Terrace tank of 5000 ltrs capacity found provided against required 25000 ltrs capacity.
8. Terrace pumps found nonfunctional.
9. Dully fill form J & Building detail form are not submitted.

In view of the above, fire safety certificate cannot be issued. You are advised to rectify the said shortcomings under intimation to this department for taking further necessary action.

Yours faithfully,


(Atul Garg)
(Director)

Delhi Fire Service

o/c


10/7/23

Copy to:-

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054