



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



C-29

DDA/PT.

No.F6/DFS/MS/School/SZ/2023/ 375

Dated: 17/07/2023

To

The Principal,  
New Mother Saraswati School  
G-657, Sangam Vihar, New Delhi-62.

**Sub:-** Regarding renewal of Fire Safety Certificate in respect of M/s New Mother Saraswati School located at G-657, Sangam Vihar, New Delhi-62.


Sir,

With reference to your Email dated 27.06.2023 on the subject cited above, it is informed that the school building was inspected by Assistant Divisional Officer (M. Road) from this department on 10.07.2023 in the presence of Mr. Madan Mohan Sharma (Manager) and it was observed that the building which was earlier comprised of Ground + 2 upper floors is now comprised of Ground + 4 upper floors. Hence is a case addition/alteration. The fire and life safety requirements are therefore applicable as prescribed in Unified Building Byelaws 2016 and National Building Code 2016 as per which following shortcomings were observed:-

1. Width of staircase of 1.50 meters width each shall be provided in the building.
2. Hose reel connecting pipe not as per the standard fire norm.
3. Hose reel found not functional.
4. 2 nos. of continuous staircases to terrace must be provided.
5. Fire pump having capacity 220 LPM provided against the requirement of 450 LPM.
6. Overhand tank capacity 2,500 liters provided against the requirement of 10,000 liters.
7. Exit signages not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

  
(Atul Garg)  
Director

Delhi Fire Service

12/7/23

**Copy to:-**

1. The Dy. Director of Education, GNCT of New Delhi DISST. South Block-C, Defence Colony, New Delhi-24.

2. Executive Engineer (Bldg) - For height verification.  
South Zone, MCD