

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

No. F6/DFS/MS/2023/SZ/ 1484  
To

Dated: 18/07/2023

Ms. Rashmi Bajaj,  
A-118, New Friends Colony,  
New Delhi

Sub: - Regarding issuance of Fire Safety Certificate in r/o B-26, Okhla Industrial Area, Phase-II, New Delhi- 110020.

Sir,

This has reference to with letter received through Outdoor diary no 2554 dated 17/06/2023 on the subject above. In this connection, it is to inform you that the premise was inspected by the concern nominated authority of this department on 04/07/2023 in the presence of Ms. Pragati Jain to check the compliance of fire safety arrangements from fire safety point of view and following shortcomings were observed:

1. The Fire Check door found damage or leaked.
2. Smoke ventilation system provided but found nonfunctional.
3. First aid hose reel provided but found nonfunctional.
4. Automatic detection system provided but found nonfunctional.
5. MOEFA not provided.
6. Automatic sprinkler system provided but found nonfunctional.
7. Internal hydrant provided but found nonfunctional.
8. Fire fighting pumps are provided but found nonfunctional.
9. Exit signage found removed.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

  
(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

