



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No.F6/DFS/MS/School/SZ/2023/280

Dated: 20/07/2023

To

The Principal,
M/s Cosmos School,
Harsh Vihar, Meethapur, Badarpur,
New Delhi-110044.

Sub:- Regarding issuance of Fire Safety Certificate in respect of Cosmos School located at Harsh Vihar, Meethapur, Badarpur, New Delhi-110044.

Sir,

With reference to your email dated 28.02.2023 on the subject cited above, it is informed that the school building was inspected by Assistant Divisional Officer (M. Road) from this department on 11.07.2023 in the presence of Mrs. Shushila Rana (Vice Pricipal) and it was observed that the building is comprised of Ground + 3 upper floors. During inspection following shortcomings were observed:-

1. Alternate staircase should not be approachable through occupied area.
2. Hose reel found not functional.
3. Fire pump found not functional.
4. Overhand tank capacity 8,000 liters provided against the requirement of 10,000 liters.
5. Exit signages found removed.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Atul Garg)

Director

Delhi Fire Service

8/17 W R

Copy to:-

1. The Dy. Director of Education, GNCT of New Delhi DISST. South Block-C, Defence Colony, New Delhi-24.