

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI- 110001**

No. F6/DFS/MS/GH/2023/SZ/ 343

Dated: 17/07/2023

To,

The Joint Commissioner of Police, 1<sup>st</sup> Floor,  
Licensing Unit, Police Station, Defence  
Colony, New Delhi-110064

**Sub: -** Regarding issue of "Fire Safety Certificate" from fire safety point of view in r/o M/s Hotel Malbork Inn, A-3/249, Janakpuri, New Delhi-110058.

Sir,

Please refer to your letter ID No. 2023062611575 dated 28/06/2023 on the subject cited above. In this connection this is to inform you that officers concerned of this department inspected the building to verify the fire safety arrangements in accordance with the rules. At the time of inspection Sh. Jaspal Singh (Manager) was present and it was observed that the building is comprised of basement (Super market), stilt floor (reception & partially covered) ground floor (Storage), first floor ( 4 guest rooms), Second floor (4 guest rooms) & third floor 4 guest rooms) at one side and have following shortcomings:-

1. First aid hose reels provided but not functional.
2. Carbon Monoxide detection system not provided as per gazette notification.
3. First aid hose reels provided but not functional.
4. Down comer system provided but not functional.
5. Fire pump provided but not functional at terrace.
6. Exit signages are not provided.
7. One side of rooms not completely sealed properly.
8. Stilt floor not completely vacated.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk & liability of the owner/occupier. The Licensing Authority/Statutory Authority may be take suitable necessary action as deemed fit.

Yours faithfully

(Atul Garg)

**Director**

Delhi Fire Service

Copy to:-

1. The Manager,  
M/s Hotel Malbork Inn, A-3/249,  
Janakpuri, New Delhi-110058.