



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

C-13
7/6
आपदादीन
अमृत महोत्सव

DFA/FT

No.F6/DFS/MS/School/SZ/2023/279

Dated: 20/07/2023

To

The Principal,
M/s Neha Public School
H. No.-623, Gali no. 12, L-1, Block (Near Budh Bazar),
Sangam Vihar, New Delhi-62.

Sub:- Regarding issuance of Fire Safety Certificate in respect of M/s Neha Public School located at
H. No.-623, Gali no. 12, L-1, Block (Near Budh Bazar), Sangam Vihar, New Delhi-62.


Sir,

With reference to your email dated 26.06.2023 on the subject cited above, it is informed that the school building was inspected by Assistant Divisional Officer (M. Road) from this department on 10.07.2023 in the presence of Mr. Tushar Chhikara (President) and it was observed that the building which was earlier comprised of Ground + 1 upper floor is now comprised of Ground + 2 upper floors, hence is a case addition/alteration. During inspection following shortcomings were observed:-

1. Width of staircase of 1.50 meters each shall be provided in the building.
2. Hose reel at ground floor shall be provided.
3. Fire pump having capacity 220 LPM provided against the requirement of 450 LPM.
4. Overhand tank capacity 2,000 liters provided against the requirement of 10,000 liters.
5. Exit signages not provided.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(Atul Garg)
Director

Delhi Fire Service

Copy to:-

1. The Dy. Director of Education, GNCT of New Delhi DISST. South Block-C, Defence Colony, New Delhi-24.

18/7/23