

C-36

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
DIRECTORATE OF DELHI FIRE SERVICE: NEW DELHI – 110001

No. F 6/DFS/MS/BP/2023/ 361

Dated: 12/07/2023

To,

The Executive Engineer (Bldg.) HQ
Municipal Corporation of Delhi,
9th floor, Civic Centre, Minto Road
New Delhi 110002

Subject: Regarding clearance of building plans from fire safety point of view in r/o addition/
alteration in the existing school for differently abled persons at Pkt-II, Sector-D,
Vasant Kunj, New Delhi-110070.

Sir,

Please refer your ID No. 10116379 dated 05.07.2023 on the above cited subject. In
this connection, this is to inform you that the online building plans in respect of proposed
building have been scrutinized by this department from fire safety point of view. Following
shortcomings are observed in the plans:

1. The occupancy mentioned in CAF is not matching with the plans.
2. The addition/ alterations are not clearly shown on the plans.
3. The exits are not arranged as per clause 7.5.10 of UBBL 2016.

In view of above, the case is rejected.

Yours faithfully,


(Atul Garg)

Director

Tel. No. 23414000

