

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/2023/SZ/ 1493

Dated: 18 / 07 /2023

To

The Authorised Signatory, Prius Commercial Pvt. Ltd., Plot No. D-3 & P3B, Saket District Centre, Saket, New Delhi-110017.

Sub: Regarding issuance of Fire Safety Certificate in r/o Prius Commercial Pvt. Ltd., Plot No. D-3 & P3B, Saket District Centre, Saket, New Delhi-110017.

Sir,

This has reference with your letter received through outdoor diary no 2124 dated 22/05/2023 on the subject cited above. In this connection, it is to inform you that the inspection of above said building have been carried out by the officer concerned of this department on 12/07/2023 and observed to verify the fire safety measures installed in the building. During inspection, following points were observed:

1. The Fire Check doors self closing device found removed.

2. Smoke ventilation system provided but found nonfunctional.

3. 4th floor of the building is under maintance.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours Faithfully

DELHI FIRE SERVICE