

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/EH/2023/SZ/ 165

Dated: 18/07/2023

To,

The Dy. Health Officer,  
Public Health Department, MCD,  
Aurobindo Marg, Green Park,  
New Delhi 110016

Sub: Regarding issuance of Fire Safety Certificate in r/o M/s Sodexo India Services Pvt Ltd. Co International Management Institute, B-10, 30 & 31 Qutab Institutional Area, Tara Crescent, New Delhi-110016

Sir,

This was reference to MHA Portal ID 2023022402536 dated 27/02/2023 & letter no nil dated 28/03/2023 on the subject cited above. It is to inform you that the premise was inspected by the concern officer of this department on 12/07/2023 in the presence of Mr. Sunil Kumar to ascertain the availability and operability of the fire prevention and fire safety measures. During the course of inspection, it is observed that the said eating house is located at ground floor in the building comprised of basement, ground plus three upper floors. The following shortcoming observed were noticed:-

1. Fire check doors self closing device are found missing in the basement.
2. Smoke ventilation system not functional in the basement.
3. Automatic sprinkler system found removed at some places in the basement.
4. Exit signature found removed at some places.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

Copy to:-

1. The Authorized signatory, International Management Institute, B-10, 30 & 31 Qutab Institutional Area, Tara Crescent, New Delhi-110016