

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No.F6/DFS/MS/2023/School/376

Dated..19..10.7/2023

To,

The Principal,  
Tagore Modern Public School,  
Motia Khan, Near DDA Office,  
New Delhi.

Sub: Regarding renewal of FSC in r/o Tagore Modern Public School at Motia Khan, Near DDA Office, New Delhi.

Sir,

This has reference to your letter no. nil dated nil, on the subject cited above. In this regard, it is to inform you that the site was inspected by the officer concerned of this department on 13/07/2023 in the presence of Principal and the following shortcomings were observed:-

1. Fire extinguishers are due for refilling.
2. Hose reel found non functional.
3. Pump found non functional.

In view of above, Fire Safety Certificate (FSC) cannot be considered at this stage. Therefore, it is requested to rectify the above shortcomings at the earliest for further consideration in the matter inform to this department.

Yours faithfully

  
(Atul Darg)  
DIRECTOR  
Delhi Fire Service

Copy to:-

1. The Director (Education), Govt. of NCT, Old Sectt. Delhi - 54.