

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001**

No. F.6/DFS/MS/GH/2023/SZ/ 346

Dated: 17/07/2023

To

The Addl. Commissioner of Police (Lic/Unit),
1st Floor, P.S. Defence Colony,
New Delhi-110049.

Sub: Regarding issuance of FSC in r/o M/s The GRD Suites at Plot No AB-250/1, Khasra No 423, Gali No 6A, Mahipalpur Extn., New Delhi-110037

Sir,

This is in reference with **MHA Portal ID 2023041106070** dated **03/05/2023** on the subject cited above. In this connection, it is to inform you that the premise have been inspected by officer concerned of this department on 12/07/2023 in the presence of Mr. Pinak Sethi (Manager) and the following shortcoming observed were noticed:-

1. First Aid Hose reel provided but found nonfunctional.
2. Sprinkler system in basement not functional.
3. Terrace level fire fighting pump capacity 450 LPM not functional.
4. Exit signage found removed at some places.
5. The occupancy above 3rd floor is not allowed as per clause 7.31 of UBBL 2016.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE