

C/67

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F.6/DFS/MS/NDZ/2023/1502

Dated: 18/07/2023

To

Sh. Rajeev Yadav,
Times of India Building,
Bahadurshah Zafar Marg,
New Delhi.

Sub: - Regarding renewal of fire safety certificate in r/o Times of India Building, Bahadurshah Zafar Marg, New Delhi.

Sir,

This has a reference to your letter no. **nil** dated **nil**, on the subject cited above. In this connection, it is to inform you that the premises was inspected by the officers concerned of this department on 11/07/2023 in the presence of Mr. Vikash and observed that the following shortcomings are not complied -

1. Fire check doors not provided at some floors.
 2. Smoke management in basement found nonfunctional.
 3. Detectors are not provided at some floors.
 4. Hose reel & hydrant are under installation.
 5. Sprinkler system is required to be provided in left out areas.
 6. MOEFA & PA system is not provided.
 7. Diesel/ Engine pump found nonfunctional.
 8. Exit signages & lift signage's are not provided.
 9. Fire man lift switch is not provided.
 10. Pumps are not in auto start provisions.
 11. Fire Control room is not provided.
- Further, some portion of building is under renovation as well.

In view of above shortcomings, the renewal of fire NOC cannot be considered at this stage. Therefore you are requested to rectify the above shortcomings at the earliest for further consideration in the matter.

Yours faithfully

(Ajul Garg)
DIRECTOR
Delhi Fire Service

Copy to:-

1. The Commissioner, MCD, Civic Centre, New Delhi.