



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F.6/DFS/MS/BP/2023 /168

Dated: 21/07/2023

To,

The Chief Architect
DMRC, Metro Bhawan
Barakhamba Lane Connaught place
New Delhi-110001.

**Sub: Examination of building plans from fire & life safety point of view in r/o
Construction of Elevated Bhajanpura Metro Station, Delhi.**

Sir,

Please refer your online building plans ID No. DMRC/Fire/98/2023/06/322 dated 26.06.2023 on the subject cited above. In this connection, this is to inform you that the referred building plans in r/o proposed construction of Elevated Metro Station at Bhajanpura, Delhi have been scrutinized by this department from fire and life safety point of view and following shortcomings are observed: -

1. All around 06 meter wide motorable road for fire tender movement is not clearly shown in the plan as per clause 8.2 of UBBL-2016.
2. The exits are not arranged as per clause J-5.2 of NBC-IV, 2016.

In view of the above, the case is rejected.

Yours faithfully,


(Atul Garg)
DIRECTOR
011 - 23414000
BG C B