

c-176

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F.6/DFS/MS/BNQT./2023/SZ/180

Dated: 21/07/2023

To,
The Manager,
M/s Golden Gate Banquet Hall,
Plot No. B-18, Maya Puri, New Delhi.

Sub: Regarding renewal of Fire Safety Certificate in respect of M/s Golden Gate Banquet Hall,
Plot No. B-18, Maya Puri, New Delhi.

Sir,

This has reference to your Online ID No. 2023062211355 dated 23/06/2023 on the subject cited above. In this connection this is to inform you that the above mentioned building was inspected by the officers concerned of this department on 10/07/2023. At the time of inspection Sh. Rohit Kalra (Owner) was also present at site. During the course of inspection it was observed that the building is comprised of Basement, ground plus one upper floor but banquet hall is on GF & FF only and have following shortcomings:-

1. An Additional Staircase Having Width 2.0 M not provided.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk & liability of the owner/occupier. The Licensing Authority/Statutory Authority may be take suitable necessary action as deemed fit.

Yours Faithfully,



(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

f. ole
h