

C-2

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE**  
**NEW DELHI- 110001**

Nó. F6/DFS/MS/School/2023/SZ/285

Dated: 21/07/2023

To,

The Manager,  
Good Luck Public School, B-97,  
Rama Park, Uttam Nagar, New Delhi-110059.

**Sub:** - Regarding issue of "Fire Safety Certificate" from fire safety point of view in r/o Good Luck Public School, B-97, Rama Park, Uttam Nagar, New Delhi-110059.

Sir,

Please refer to your letter No. G/P/S/1001 Dated- 09/07/2023 on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the building to verify the fire safety arrangements in accordance with the rules. At the time of inspection Sh. Anil Kumar (Manager) was present and it was observed that the building is comprised of ground plus four upper floors. & half portion constructed at fifth upper floor and have following shortcomings:-

1. Both staircases shall be provided 1.5 m wide upto terrace.
2. Corridor having 1.25 m in place of 1.5 m.
3. Door width 1.0 m not provided.
4. First aid hose reel not provided.
5. MOEFA & PA system not provided.
6. Down comer system not provided.
7. Fire pump not provided at terrace.
8. Overhead water tank 10,000 liters not provided.
9. Exit signage's are not provided.
10. As building is ground plus fifth upper floors and seems to high rise, hence you are requested to submit approved plans for the same.

In view of above shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk & liability of the owner/occupier. The Licensing Authority/Statutory Authority may be take suitable necessary action as deemed fit.

Yours faithfully,

(Anil Garg)

Director

Delhi Fire Service

*[Handwritten signature]*

Copy to:-

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054  
(With a request to take further action as school does not have fire NOC)
2. Executive Engineer, South West Zone-MCD-For information & with the request to measure & apprise the height of above said building to this department.

Testing.