

C-5



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No.F6/DFS/MS/2023/EH/395

Dated 21/07/2023

To

The Joint Commissioner of Police/ Lic,
1st Floor, Licensing Unit, Police Station
Defence Colony, New Delhi.

Sub: - Regarding issuance of fire safety certificate in r/o M/s Moets Bar Be Cue Restaurant located at 1DDA Market, Alipur Road, Delhi-110054.
Sir,

This has reference to online mha portal I'd. No. 2023062711631 dated 28.06.2023 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 12.07.2023 in the presence of Mr. Patrick (Manager) to verify the fire safety measures not installed in the building and observed that the building is comprised of ground & first floor but restaurant is running at ground floor only. Your request for FSC is rejected under Rule 37 (3) due to following shortcomings.

1. Smoke ventilation systems not provided.
2. Hose reel hose not provided.
3. MOEFA System not provided.
4. Internal hydrants not provided.
5. Terrace level fire pump capacity of 450 lpm not provided.
6. Overhead water storage tank capacity of 20,000ltrs for firefighting purpose not provided.
7. Exit signage not provided in the building.
8. Highly combustible material foam and plastic fencing use in all around seating area which needs to be removed.

Keeping in view of above, grant of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of restaurant is at your own risk & responsibility.

Yours faithfully

(Anil Garg)
Director

Ph: 011-23414000

Copy to:-

1. The Manager, M/s Moets Bar Be Cue Restaurant located at 1DDA Market, Alipur Road, Delhi-110054.