

c-30

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No.F6/DFS/MS/NDZ/2023/EH/409

Dated: 25/07/2023

To

The Manager
M/S CE LA VIE (A Unit of Vaashpik Food Enterprises),
H-11, Ground & Mezzanine Floor,
Outer Connaught Circus, New Delhi.

Sub: Regarding issuance of FSC in r/o M/S CE LA VIE (A Unit of Vaashpik Food Enterprises), H-11, Ground & Mezzanine Floor, Outer Connaught Circus, New Delhi.

Sir,

This has reference to online id no. 2023070512044 dated 09.07.23, on the subject cited above. In this connection it is to inform you that the site was inspected by the officers concerned department on 14/07/2023 in the presence of Mr. Santosh and following shortcomings were observed:-

1. Hose reel & hydrant system found nonfunctional.
2. ~~Fire~~ Pump found non functional.
3. MOE/FA found removed.
4. Overhead tank found empty.
5. Exit signages found removed.

In view of above, the case is rejected. Therefore, you are requested to rectify the shortcomings for further consideration in the matter.

Yours faithfully,


(Atul Gargy)
DIRECTOR
Delhi Fire Service

Copy to:-

1. The Addl. Commissioner of Police (Lic.), Licensing Unit, Defense Colony Police Station, New Delhi.