

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/EH/2023/SZ/ 404

Dated: 25/07/2023

To

The Dy. Health Officer, MCD,
Public Health Department, Green Park,
Aurobindo Marg, New Delhi 110016.

Sub: Regarding issuance of Fire Safety Certificate in r/o M/s Circle café and bar (A unit of Bliss Hospitality Pvt Ltd) at F-1, First Floor, Kalkaji, New Delhi 110019.

Sir,

This has reference with MHA Portal ID 2023070311874 dated 08-07-2023 on the subject cited above. In this concerned, it is to inform you that the premise was inspected by the concern nominated authority of this department on 20/07/2023 in presence of Mr. Rahul (Manger) to verify the fire safety measures installed in the building and observed that the building is comprised of Basement, Ground + Three upper floor but restaurant running at First Floor only. Accordingly fire safety arrangement were tested / checked and found following observation.

1. The second staircase / rear side having width varies from 1.20 mtr to 1.50 mtr against the required width of 1.50 mtr clear out as per UBBL 2016.
2. Exit Signage not provided.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

07/07/23