



Yours faithfully

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI- 110001

No. F6/DFS/MS/WZ/EH/2023/401

Dated: 24/07- /2023

To.

The Joint Commissioner of Police, Licensing Unit, 1" floor, Police Station, Defence Colony, New Delhi. addlcp.lic-dl@nic.in

Subject: Regarding renewal of NOC from fire safety point of view in respect of Punjabi

Zaika. Located at 359A, Ground Floor, Raja Park, Shakur Basti, New Delhi – 110034.

Sir,

This is in reference to the online application received through MHA portal vide online ID No. 2023070411905 dated 05/07/2023 on the subject cited above. In this connection, it is to inform you that the premises was re - inspected by officer concerned of this department on 16/06/2023 in the presence Sh. Arvind Singh to check the shortcomings already issued by this deptt. vide letter No.- F6/DFS/MS/ EH/WZ/2023/317 dated 16/06/2023.

During inspection, it has been observed that said restaurant is running at Ground Floor in a building comprised of Ground + 03 Upper Floors. Fire safety arrangement of the restaurant such as Fire Extinguishers & Smoke Management System is provided. However, the status of shortcomings are as under.

S. no.	Shortcomings	Status
1.	Main Fire Pump capacity of 450lpm is provided but not on auto mode.	Rectified
2.	Exit Signage's is not provided.	Rectified
3.	During inspection, it has been observed that first & second floor is now using as banquet hall shall be closed.	Not Rectified

In view of above Shortcomings the application for renewal of Fire safety Certificate is not considered at this stage & rejected. The occupancy of the Building/ premises in absence of requisite fire safety arrangements shall be at the risk and liabilities of the Owner/occupier. The licensing issuing authority/statutory authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements.

Copy to: -

1. The Owner/Occupier, M/s. Punjabi Zaika. Located at North West Avenue Club Road, Punjabi Bagh, New Delhi-110026. Online application ID- 2023070411905 dated

 The DHO, MCD, West Zone, Shivaji Enclave, Raja Garden, New Delhi- 110027. dhowest zone@gmail.com).