

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/MS/EH/2023/SZ/ 399  
To

Dated 21/07/2023

1. The Additional MHO (South) 12 <sup>th</sup> floor, Dr. SPM Civic Center, JHL Marg, New Delhi 110001	2. The Dy. Commissioner of Police Licensing Branch, 1 <sup>st</sup> Floor, PS Defence Colony, New Delhi -49 Email: <a href="mailto:addlcp.lic-dl@nic.in">addlcp.lic-dl@nic.in</a>
--	--

**Sub:** - Regarding issuance of fire safety certificate in r/o M/s RPM 2.0 (A Unit of Colours of Life) situated at 40, Community Centre, Basant Lok, Vasant Vihar, New Delhi - 110057

Sir,

This has reference to with complaint received through Email dated 14/07/2023 on the subject cited above. In this connection, this is to inform you that a surprise visit of the above mentioned premise was conducted by the officer concerned of this department on 19.07.2023 in the presence of Mr. Peter to verify the fire safety measures installed in the building and observed that restaurant is running at mezzanine & First floor in the building comprised of ground, mezzanine and three upper floors. During the course of inspection, the following points were observed:

- 1 First Aid Hose reel hose provided but found nonfunctional.
- 2 MOEFA found removed.
- 3 Automatic sprinkler system provided but found nonfunctional.
- 4 Internal Hydrants provided but found nonfunctional.
- 5 Terrace level Fire Pump capacity of 450 LPM provided but found nonfunctional.
- 6 Overhead tank capacity 5,000 ltrs provided but it has also been utilizing for kitchen and other purposes connections.
- 7 Exit signage found removed.

In view of above said Shortcomings / observations it is decided that FSC which was issued on 12.05.2022, is suspended. The department shall review the availability of the Fire Safety and other parameters/ conditions of the FSC in the said premise. Therefore, till such time the FSC may please be treated as suspended and operation of the restaurant may not be allowed in the interest of public safety, till the restaurant gets/ obtains fresh FSC from this department.

Yours faithfully

(ATUL GARG)  
DIRECTOR

DELHI FIRE SERVICE  
o/c

Copy for information and n/a to:

1. The DCP South-West, Basant Lok Vasant Vihar, New Delhi 110070. Email [dcp.sw@delhipolice.gov.in](mailto:dcp.sw@delhipolice.gov.in)
2. The SHO (Vasant Vihar) South-West District, New Delhi.
3. Concerned Owner/occupier RPM 2.0 (A Unit of Colours of Life) situated at 40, Community Centre, Basant Lok, Vasant Vihar, New Delhi 110057 ([rpmvv40@gmail.com](mailto:rpmvv40@gmail.com))
4. Mr. Rojesh Jacob (Email Id [rojeshjac7@gmail.com](mailto:rojeshjac7@gmail.com))