

c/45

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI – 110001**

NO. F6/DFS/MS/SZ/2023/ 1549

DATED: 25/07/2023

To,

The President / Secretary
Sapna Ghar CGHS Ltd.
Plot No-06B, Sector-11, Dwarka,
New Delhi-110078

Subject: - Complaint of fire fighting equipments in r/o Sapna Ghar CGHS Ltd. Located at Plot No-06B, Sector-11, Dwarka, New Delhi-110078.

Sir,

Please refer to your Email dated-15/06/2023 on the subject cited above. In this connection it is to inform to you that the above said residential building has been inspected by the officer concerned of this department on 30/06/2023 in the presence of Sh. Jitender Kumar for fire safety point of view.

During the course of inspection followings shortcoming have been observed:-

1. Internal road around the building found blocked/encroached. Trimming of trees must be done to ensure the free movement of fire vehicle.
2. Staircases must be kept free from any obstruction & must not be locked at terrace.
3. Hose Reels & Hydrants system found nonfunctional.
4. PA system found nonfunctional.
5. All the Pumps at terrace level found nonfunctional.
6. Couplings/ branches and hoses found missing at some floors.
7. Exit signage's found removed at some places.

You are requested to comply the abovementioned shortcomings under intimation with this department.

In view of the above shortcomings renewal of Fire Safety Certificate cannot be considered at this stage.

Yours faithfully,


(Aul Garg)
(Director)
Delhi Fire Service

Copy to:-

1. The Joint Director, DDA, Vikas Sadan, INA, New Delhi.
2. Sh. Munish Sachdeva, Flat No. 273, Block-2, Sapna Ghar CGHS Ltd. Located at Plot No-06B, Sector-11, Dwarka, New Delhi-110078