

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/College/WZ/2023/39

Dated: 26/07/2023

To,

The Principal,  
Bharati Vidyapeeth's College of Engineering,  
A-4, Paschim Vihar, Rohtak Road,  
New Delhi- 110063.

Subject: Regarding Issuance of NOC from fire safety point of view in r/o. Bharati Vidyapeeth's College of Engineering, A-4, Paschim Vihar, Rohtak Road, New Delhi-110063.

Sir,

Please refer to your Email dated: - 12/07/2023 on the subject cited above. In this connection, it is to inform you that the premises was inspected by the officer concerned of this department on 21/07/2023 in presence of Sh. Anuj (Maintenance Incharge) to check the shortcoming already issued by this department vide letter no. F6/DFS/MS/College/WZ/2023/30 dated 19/06/2023. However, the status of shortcoming is as under:-

During inspection, it has been observed that the college is running at Ground Plus 04 upper floors, one upper floor now addition earlier it was ground plus 03 upper floors, Fire safety arrangements such as Fire Extinguishers, MOEFA etc provided. However the following shortcomings were observed.

S. no.	Shortcomings	Status
1.	Width of internal road of 06 mtr is not provided.	Not Rectified
2.	Widths of staircases are 1X 1.50m, 1X 1.30m, 2 X1.95m is provided against requirement of 2 X 2.1m, 1 X 1.5 m, 1X 1.8 mtr.	Not Rectified
3.	Fire Check doors are not provided.	Not Rectified
4.	Exit Signage's is not provided.	Not Rectified

In view of above, the application for issuance of fire safety certificate is not considered & rejected. The occupancy of the building/premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the owner/occupier.

Yours faithfully

(Atul Garg)  
Director