

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F.6/DFS/MS/2023/SZ/College/36
To

Dated: 25/07/2023

Dr. Monica Chopra,
Campus Director,
Delhi Skill and Entrepreneurship University,
Okhla-II, Campus, Okhla Ph-II, New Delhi 110020

Sub: - Regarding Issuance of fire Safety Certificate in r/o Delhi Skill and Entrepreneurships University at Centre For healthcare allied Medical and Paramedical Sciences, (Camps) Okhla - II, Industrial Area, Phase-II, New Delhi 110020.

Sir,

This has reference with letter no 25(03)/DTTDC/Engg./EE/E/2023-24/141 dated 23/06/2023 on the subject cited above. In this regard it is to inform you that FSC under Rule 35 of Delhi Fire Service Rules-2010 is issued only for those premise which are referred by building Authority/local authority as specified in section 2 (q) of DFS Act 2007 to this department.

In this regard you are advised to first apply with concern building sanctioning authority with a request to forward following documents to this department to ensure proper implementation of fire prevention & fire safety measures as applicable under Rule 33 of DFS-2010 pm the said premise/building.

1. Sanctioned/ Completion plans.
2. As built plan through building/local Authority, if sanctioned/Completion plans are not available.
3. Initial date of operation of Occupancy in this building.

Further it is also pertinent to mentioned here that the above said observation has already been issued and communicated to you vide our earlier letter of dated 23/06/2022.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully


(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to: -

1. The Commissioner South Delhi Municipal Corporation, E-1,9th Floor, Dr. S.P.M. Civic Centre, JLM Marg, New Delhi-110 002 (Email ID commissioner-sdmc@mcd.gov.in)