

C-45

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F-6/DFS/MS/2023/SZ/GH/366

Dated 26/07/2023

To
The Joint Commissioner of Police
Lic/Branch, 1st Floor, Police Station
Defence Colony, New Delhi-110049.

Sub: - Regarding issuance of fire safety certificate in r/o M/s Lloyd House II, Guest House at C-6,
Kalkaji, New Delhi -110019

Sir,
This has reference to your MHA Portal ID 202371512591 dated 15-07-2023 on the subject cited above. In this connection this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 21.07.2023 in the presence of Sh. Mukesh Sharma (Manager) to verify the fire safety measures installed in the building and observed that the Guest house is running at Ground plus two upper floors. Accordingly fire safety arrangement were tested / checked and found following observation.

1. Carbon Monoxide detector not provided as per clause 7.31 of UBBL 2016.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Atul Garg