

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/2023/ 1559

Dated: 27/07/2023

To,

Sh. B. S. Garcha,
Major
Officiating Officer Commanding,
500 Independent Signal Company,
Opposite HQ Western Air Command
Near Asmara Lines,
Delhi Cantt-110010.

Sub: Regarding fire clearance in r/o National Network Center at Delhi Cantonment.

Sir,

Please refer to your letter No. 159/Sigs/03/NFS/UNMS dated 12.06.2023 and 159/Sigs/03/NFS/UNMS dated 29.05.2023 respectively on the subject cited above. In this connection, the matter is examined and following shortcoming are observed:

1. The plans are not signed/ stamped/ forwarded by the concerned local authority.
2. All around 06 meter motorable road with 09 m turning radius for fire tender movement is not provided as per clause 8.2 of UBBL 2016.
3. The staircases are not discharging as per clause 7.11 (l) of UBBL 2016.
4. The entry to the staircase is not through firecheck door as per clause 7.11(j) of UBBL 2016.
5. The lift lobby is protected with fire check door as per clause 4.2.7 of NBC part 4.
6. Travel distance is not meeting the requirement as per clause 7.8.2 of UBBL 2016.
7. Width of exit doors are not clearly mentioned.

In view of above, the case is rejected and the plans are returned herewith.

Yours faithfully,

(Atul Garg)
Director

011- 23414000

