



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

No. F.6/DFS/MS/EH/2023/NDZ/417

Dated: 28/7/2023

To,

The Joint Commissioner (Lic.)
1st floor Police Station Defence Colony,
New Delhi

Subject:- Regarding issuance of Fire Safety Certificate in r/o M/s Al Quresh Foods (Eating House) located at Plot No. V-290, Main Road No. 66, Vijay Park, Maujpur, Delhi-110053.

Sir,

With reference to your online MHA application No. 2023042707626 dated 06/07/2023 on the subject cited above. In this connection, it is to inform you that the officers concerned of this department have carried out the inspection of premises from fire safety point of view in presence of Sh. Aman Qureshi, Manager on dated 20/07/2023. The building comprised of ground, mezzanine plus three upper floors. Proposed eating house is on ground and mezzanine floor only. Following shortcomings were observed during the time of inspection.

1. Two staircases of width 1.50 meter each not provided on Mezzanine floor.
2. Two door of width 2.00 meter and 1.20 meter provided against the requirement of 1.50 meter each.
3. Second door passing through the kitchen.
4. Kitchen should be segregated by the means of fire check door.
5. Fire Extinguisher not provided.
6. First Aid hose reel not provided.
7. MOEFA not provided.
8. Down-comer not provided.
9. Terrace pump of capacity 450 LPM with 40 meter head not provided.
10. Overhead water tank 20,000 liters not provided.
11. Exits signage not provided.

In view of above, the application for issuance Fire Safety Certificate is rejected. The occupancy of building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to:-

1. Sh. Aman Qureshi
Al Quresh Foods (Eating House)
Plot No. V 290, Main Road No. 66, Vijay Park, Maujpur, Delhi-110053
2. Dy. Health Officer, MCD
Shahadara North Zone near Shyam Lal College, Delhi 1110032
MHA ID 2023042707626