



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आजादी
अमृत महोत्सव

No.F6/DFS/MS/WZ/2023/ 1578

Dated: - 27/07/2023

To,

Sh. Ajay Khatri,
AGM (Fire & Safety),
IGL Bhawan, Plot No. 4, Community Centre,
Sector-9, R.K. Puram, New Delhi-110022.

Subject: Regarding renewal of Fire Safety Certificate in respect of CNG Dispensing Station, Lok Nayak Puram, Plot No. 3, Site No. 1, Bakkarwala, New Delhi-110041.

Sir,

This has reference to your letter no. IGL/F&S/2023/15/93/1 dated 03.07.2023, on the subject cited above. In this connection, it is to inform you that the CNG Station building was re-inspected by the officer concerned of this department on 18.07.2023 in the presence of Sh. Chintvan Vyas (Add. Manager, Fire & Safety) to check workability/functionability of Fire safety system provided in the building. During the course of inspection, following shortcoming has been observed:-

1. Advance fire water mist cum foam trolley found non-functional.

In view of the above shortcoming, the application for renewal of Fire Safety Certificate cannot be considered at this stage & rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

(Atul Garg)

Director

011-23414000

pc

26/7

26/07/23