



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F-6/MS/DFS/EH/2023/421

Dated: 31/07/2023

To,

Mr. Vaibhav Nagori,
Eleved Lifestyle Pvt. Ltd,
Plot No.-16/48 (GF), Diplomatic Enclave Malcha Marg,
Chanakyapuri, New Delhi- 110021.

Sub: - Inspection report in R/o: **Eleved Lifestyle Pvt. Ltd. located at Plot No.-
16/48 Ground Floor, Diplomatic Enclave Malcha Marg, Chanakyapuri, New
Delhi-110021**

Sir,

Please refer to your letter no through MHA ID- 2023070411968 dated 14/07/2023 on the subject cited above. In this connection, it is to inform you that the said premise was inspected by the team of officers concerned of this department on 22/07/2023 in the presence of Mr. Rajiv and observed that building comprised of Basement, Ground, Loft & One upper floor. Proposed eating house is on ground floor only.

Following shortcomings were observed during the time of inspection:-

1. Common staircase not segregated at ground floor.

Keeping in view of above shortcoming, the application for issuance of Fire Safety Certificate cannot be considered at this stage you are requested to rectify above mentioned shortcoming under intimation to this department for taking necessary action this matter.

Yours faithfully,


(ATUL GARG)
DIRECTOR
Delhi Fire Service