



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/ms/Sch/SZ/2023/296

Date: 28/07/2023

To,

Mr. Raj Kumar (Principal),
Ganesh Shankar Vidyarathi,
Sarvodaya Bal Vidyalaya No-1,
Sarojini Nagar, New Delhi-110023.

Sub: - Regarding grant of FSC from fire safety point of view in r/o: Ganesh Shankar Vidyarathi
Sarvodaya Bal Vidyalaya No-1, Sarojini Nagar, New Delhi-110023.

Sir,

Please refer to your letter outdoor dairy No 2352 dated-30.05.2023 on the subject cited above. In this connection, it is to inform you that the premise was inspected by the officer concerned of this department on 18/07/2023 in the presence of Mr. Raj Kumar (Principal) from fire safety point of view. The building comprised of Ground and One upper floor (Two Block). During the course of inspection, the following points / shortcomings were noticed:

1. Hose reel found but not functional at Ground Floor.
2. Hose reel hose found defective at terrace.

Keeping in view of above shortcoming, the application for issuance of Fire Safety Certificate cannot be considered at this stage you are requested to rectify above mentioned shortcoming under intimation to this department for taking necessary action this matter.

Yours faithfully,


(ATUL GARG)
DIRECTOR
Delhi Fire Service
d/c

Copy to :-

1. The Director of Education, NDMC, Palika Kendra, New Delhi- 110001.