

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**  
**NEW DELHI- 110001**

No. F.6/DFS/MS/School/2023/SZ/295

Dated: 28/07/2023

To  
The Principal,  
Govt. Boys Senior Secondary School,  
Rajokari, New Delhi 110038 (ID 1720028)


Sub: Regarding issuance of NOC/FSC in r/o Govt. Boys Senior Secondary School, Rajokari, New Delhi 110038 (ID 1720028)

Sir,  
This has reference to your letter no. GBSSS/Raj/2023/208 dated 07/07/2023 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 20.07.2023 in the presence of Mr. Ramesh Chander to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. Fire Extinguishers provided but found not refilled.
2. First aid hose reel provided but nonfunctional.
3. Terrace level Fire Pump capacity of 450 LPM x 2 provided but found nonfunctional.
4. Overhead tank capacity 10,000 ltrs found empty.
5. Exit signage found removed at some places.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,



(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

Copy to:-

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi 110054.