

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI - 110001**

NO. F6/DFS/MS/SZ/2023/1574

DATED: 27/07/2023

To,

The President / Secretary
Ahmad Kidwai CGHS Ltd.
Plot No-12 A, Sector-07,
Dwarka, New Delhi-110075

**Subject: - Renewal of Fire Safety Certificate in r/o Rafi Ahmad Kidwai CGHS Ltd.
Located at Plot No-12 A, Sector-07, Dwarka, New Delhi-110075.**

Sir,

Please refer to Email dated-10/07/2023 on the subject cited above. In this connection it is to inform to you that the above said residential building has been inspected by the officer concerned of this department on 21/07/2023 in the presence of Sh. Ravinder (Manager) for fire safety point of view.

During the course of inspection followings shortcoming have been observed:-

1. Six meter wide internal road around the building found blocked/encroached.
2. Only one ABC type fire extinguisher of 10 Kg capacity is found provided at each floor against required two fire extinguishers.
3. Hose Reels & Hydrants system found nonfunctional.
4. Hoses / Nozzles were found missing at some floors.
5. MOEFA found nonfunctional.
6. PA system found nonfunctional.
7. Sprinkler system in basement found nonfunctional
8. Pump at terrace level found nonfunctional in auto mode.
9. Dully fill form J & K are not submitted.

You are requested to comply the abovementioned shortcomings under intimation to this department.

In view of the above shortcomings Fire Safety Certificate cannot be considered at this stage

Yours faithfully,


(Atul Garg)
(Director)
Delhi Fire Service

Copy to:-

1. The Joint Director, DDA, Vikas Sadan, INA, New Delhi.