



75
आज़ादी का
अमृत महोत्सव

C-69

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI- 110001

No. F6/DFS/MS/WZ/EH/2023/ 412

Dated: 20/07/2023

To,

The Joint Commissioner of Police,
Licensing Unit, 1st floor, Police Station,
Defence Colony, New Delhi.
addlep.lic-dl@nic.in

Subject: Inspection report for renewal of Fire Safety Certificate in r/o Sagar Ratna Restaurant Pvt. Ltd. Located at Ground Floor, B-2/1, Ashok Vihar Phase-II, New Delhi – 110052.

Sir,

This is in reference to the online application received through MHA portal vide online ID No. 2023070512017 dated 11/07/2023 on the subject cited above. In this connection, it is to inform you that the premises was re - inspected by officer concerned of this department on 20/07/2023 in the presence Sh. Yogesh (Manager) to check the shortcomings already issued by this deptt. vide letter No.- F.6/DFS/MS/ EH/WZ/2023/59 dated 03/02/2023.

During the course of inspection, it was observed that the said restaurant is running at Ground Floor in a building comprised of Ground + 03 Upper Floors. Fire safety arrangement of the restaurant such as Fire Extinguishers, MOEFA, First Aid Hose Reel & Down Comer is provided. However, the status of shortcomings is as under.

S. no.	Shortcomings	Status
1.	Overhead water tank capacity of 1,000 ltrs is provided against requirement of 5,000 ltr.	Not Rectified
2.	Terrace pump capacity of 450LPM is provided but not functional.	Not Rectified
3.	Hose reel hose & Down Comer are provided but not functional.	Not Rectified
4.	MOEFA is provided but not functional.	Not Rectified
5.	Exit Signages are removed.	Not Rectified

In view of above Shortcomings, the application for renewal of Fire safety Certificate is not considered at this stage & rejected. The occupancy of the Building/ premises in absence of requisite fire safety measures shall be at the risk and liabilities of the Owner/occupier. The licensing issuing authority/statutory authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements.

Yours faithfully

(Atul Garg)
Director

Copy to: -

1. The Owner/Occupier, M/s. Sagar Ratna Restaurant Pvt. Ltd. Located at Ground Floor, B-2/1, Ashok Vihar Phase-II, New Delhi – 110052. (Online ID No. 2023070512017 dated 11/07/2023)
2. The DHO, MCD, West Zone, Shivaji Enclave, Raja Garden, New Delhi- 110027. dhowest_zone@gmail.com).