

C-23

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/2023/GH/WZ/371

Dated: 28/7/2023

To,

Mr. Ved Prakash,
House No.B-327, Saraswati Vihar,
Pitam Pura,
Delhi-110034.

Sub: Issue of FSC in r/o M/S Shri Hari Kunj P. NO. 23 UGF, FF & SF, Pocket-A, Sector--19, Rohini, Delhi-110085.

Sir,

This is in reference to online application No.2023070411951 dated 06.07.2023 on the subject cited above. The premise was inspected by the concern nominated authority of this department on 17.07.2023, in presence of **Sh. Kamlesh Patel (Manager)** to ascertain the availability and operability of the fire prevention and fire safety measures. The following shortcomings were observed:

1. The width of Staircase is 1.1 mtr against the required width of 1.50 mtr.
2. The width of corridor is 1.5 mtr against the required width of 1.80 mtr.
3. Fire Check door not provided.
4. Natural ventilation not provided in corridor.
5. Hose reel provided but not functional.
6. CO detector system not provided.
7. Terrace pump of 450 lpm is provided but not functional.
8. Building profile is not matching with detail given in CAF.

In this regard as stipulated in sub Rule (5) of Rule 35 of DFS Act-2007 & Rules 2010 it is advised the applicant to apply with a fresh application for grant of fire safety certificate under sub-rule (2) on Form "I" and it shall be accompanied with a certificate from the architect and owner or occupier that all the fire prevention and fire safety measures are duly complying with the requirements as communicated under sub-rule (4) above, for further consideration in this regard. The web links for DFS Act-2007/ Rules 2010 & Form "I" are as under:
http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/
http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Forms

Yours faithfully



(Atul Garg)
DIRECTOR

Ph; 011-23414000

Copy to:

MHA Id- No. 2023070411951 dated 06.07.2023

etc
Any