



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

CB



Dated: 28/07/2023

No. F6/DFS/MS/2023/School/ 298

To

Sh. Jai Prakash (Dy. Director of Education/ PSB)
Director, Education (Private School Branch),
Government of N.C.T of Delhi. Old Secretariat
Delhi - 110054.

Sub: - Regarding issuance of fire safety certificate in r/o Suraj International School at 25 Foota Road, Shastri Park, Phool Bagh Road, Nathupura, Burari, Delhi-110084.

Sir,

Please refer to your letter No. DE/15(1391)/Misc./North/2023/5742-5745 dated 26.06.2023 received in this department vide outdoor dairy no.3275 dated: 30.06.2023 on the subject cited above. In this connection this is to inform you that the above mentioned site was re-inspected by the officer concerned of this department on 12.07.2023 to verify the fire safety measures issued vide NBC Part- IV and observed that as per earlier inspection building was comprised of 02 blocks first block is comprised of ground floor only & second block is comprised of ground plus first floor. Now the school management has added one more floor which is under construction and current building composition is 02 blocks ground & first floors each. At the time of inspection Sh. Manoj Tyagi (Admin) was also present at site. During the course of inspection observations/ shortcomings made are as under:-

1. The width of main gate 3.50m against the requirement of 4.50m at two sides is obstructed by concert colum needs to be removed.
2. Only one staircase provided width of 1.50m both side against the requirements of 02 nos. of staircases width of 1.50m each blocks.
3. MOEFA system not provided.
4. Exit signage and floor signage not provided at strategic locations in the building.
5. As per approval the building plans, the building was comprised of 02 blocks. first block is comprised of ground floor only & second block is comprised of ground plus first floor whereas the building is constructed with 02 blocks ground & first floor each which is deviation of building plans. Hence fresh approval of building plans is required with complete building plans including fire and life safety provisions as per NBC Part- 2016 through building sanctioning authority for further consideration in the matter.

Keeping in view of above, grant of Fire Safety Certificate cannot be considered at this stage & rejected. You are requested to rectify the above mentioned shortcomings under intimation to this department; till such time running of school is at your own risk & responsibility.

Yours faithfully

(Atul Garg)

Director

Ph:-011-23414000

Copy to:-

1. The Administrative, Suraj International School located at 25 Foota Road, Shastri Park, Nathupura, Burari, Delhi-110084.