

c-52

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No. F.6/DFS/MS/GH/SZ/2023/ 368

Dated: 27/07/2023

To

The Owner/Occupier
M/s. Taksh Inn guest house, 13A/26,
WEA, Karol Bagh, New Delhi- 110005.

Sub:- Regarding renewal of Fire Safety Certificate in respect of M/s. Taksh Inn guest house, located at 13A/26, WEA, Karol Bagh, New Delhi- 110005.

Sir,

Please refer to your Online Application No. 2023051008580 dated 11.05.2023, on the subject cited above. In this connection, it is to inform you that the aforesaid guest house has been inspected by the officer concerned of this department on 17.05.2023 in the presence of Sh. Kamal Singh (Manager) to check the functionability of fire safety arrangements already provided in the guest house building.

During the course of inspection, it was observed that the said guest house is comprised of basement, ground plus three upper floors. Fire safety arrangements such as fire extinguisher, overhead water tank capacity 5,000 lts. etc. found provided. However the following shortcomings were observed as per the notification No. F.5(1897/AD/LB/2016/4053-65 dated 27.05.2019 in respect of existing building :-

1. First-Aid Hose Reel found provided but not functional.
2. MOFEA system found provided but not functional.
3. PA system found provided but not functional.
4. Automatic Fire Detection system found provided but not functional.
5. Terrace fire pump 450 LPM found provided but not functional.
6. Found Gym is running in Basement at the time of inspection which is not allowed.

In view of the above, as per the notification No. F.5(1897/AD/LB/2016/4053-65 dated 27.05.2019, the FSC issued vide letter no F6/DFS/MS/GH/SZ/2021/267 dated 29.07.2021, is rejected for renewal of FSC. In the absence of fire safety certificate this guest house is not safe from fire safety point of view. You are advised to rectify the above mentioned shortcomings and apply a fresh on MHA portal for further necessary action in this matter.

Yours faithfully


(Atul Garg)
Director

Delhi Fire Service

Copy to :-

1. The Joint Commissioner of Police (Lic.), Police Station, Defence Colony, 1st floor, New Delhi.