

C-18)

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI- 110001

No. F6/DFS/MS/WZ/EH/2023/ 424

Dated: 01/08/2023

To,

The Joint Commissioner of Police,
Licensing Unit, 1st floor, Police Station,
Defence Colony, New Delhi.
addlcp.lic-dl@nic.in

Subject: Issuance of Fire Safety Certificate in respect M/s. Boom Box Bar & lounge (A unit of Blue lighting cafe Pvt. Ltd.), C-10, 1st floor Vishal Enclave, Tagore Garden, New Delhi.-110027.

Sir,


This is in reference to the online application received through MHA portal vide online ID No. 2023071712659 dated 17/07/2023 on the subject cited above. In this connection, it is to inform you that the premises was re-inspected by officer concerned of this department on 25/07/2023 in the presence Sh. Dharamraj Tiwari (Security Manager) to check the shortcomings already issued by this depts. vide letter No.- F6/DFS/MS/WZ/EH/2023/272 dated: 24/05/2023.

During inspection, it has been observed that said restaurant is running at 1st Floor in a building comprised of Basement, Stilt, Upper ground, 1st & 2nd floor. Fire safety arrangement of the restaurant such as Fire Extinguishers & Smoke Management System is provided. However, the status of shortcomings are as under.

S. no.	Shortcomings	Status
1.	Width of door size is 1 x 2mtr & 1 x 1.20 mtr is provided against requirement of 02 x 1.5mtr each.	Not Rectified
2.	First Aid Hose Reel is provided but not functional.	Not Rectified
3.	MOEFA is not provided.	Not Rectified
4.	Internal Hydrant is provided but not functional.	Not Rectified
5.	Main Fire pump of capacity of 450 lpm is provided but not functional.	Not Rectified
6.	Overhead Water Storage tank of capacity 20,000 ltrs is provided but not exclusive for firefighting purpose.	Not Rectified

In view of above Shortcomings the application for Issuance of Fire safety Certificate is rejected. The occupancy of the Building/ premises in absence of requisite fire safety arrangements shall be at the risk and liabilities of the Owner/occupier. The licensing issuing authority/statutory authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements.

Yours faithfully,


(Atul Garg)

Director

Copy to: -

1. The Owner/ Occupier M/s Boom Box Bar & lounge,(A unit of Blue Lighting cafe Pvt. Ltd.), located at C-10, 1st floor, Vishal Enclave, Tagore Garden, New Delhi-110027. (Online ID:- 2023071712659 dated 17/07/2023).

2. The DHO, West Zone, SDMC, Shivaji Enclave, Raja Garden, New Delhi-110027. Email Id : - (dhowest zone@gmail.com).