

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F-6/DFS/MS/EH/2023/SZ/ 426  
To

Dated:- 02/08/2023

The Dy. Health Officer, (MCD)  
Public Health Officer, (Green Park Zone)  
Aurobindo Marg, Green Park, Delhi 110016.

**Sub:** - Regarding issuance of fire safety certificate in r/o M/s CABO DEIL (Unit of Alley house Kitchen and Bar Pvt Ltd, Located at Plot No 192, Ground Floor, Carrippa Marg, Khirki Extn. Gate No 2, New Delhi 110062.

Sir,

This has reference to with MHA Portal No. 2023070612065 dated 10/07/2023 on the subject cited above. In this connection, it is to inform you that the above mentioned premise was visited by the officer concerned of this department on 24.07.2023 in the presence of Mr. Prithvi (Supervisor) to verify the fire safety measures installed in the building. During inspection, following points were observed:

1. The exit doors having width of 1.50 mtr & 1.20 mtr wide provided against the required width of 1.50 mtr each.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully

  
(ATUL GARG)  
DIRECTOR

DELHI FIRE SERVICE

quw