

C-22

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110001

No: F.6/DFS/MS/School/2023/SZ/ 300

Dated: 01/08/2023

To,

The Principal,  
M.C. Primary School,  
Matiyala-I/II (Najafgarh Zone), New Delhi-110059

**Sub:** - Regarding issuance of Fire Safety Certificate in r/o M.C. Primary School, Matiyala-I/II (Najafgarh Zone), New Delhi-110059 (School ID – 1757204).

Sir,

This has reference to your letter No. 198/18/7/23 dated 18/07/2023 on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the school on 25/07/2023 to verify the fire safety arrangements in accordance with the Rules. At the time of inspection Smt. Fabeola Tirky (Principal) was present and it was observed that the school building is comprised of ground plus two upper floors and have following shortcomings:-

1. Staircases having <sup>width</sup> 1.30 & 1.40 m provided in place of 1.50 m

In view of above, the fire safety certificate cannot be considered at this stage. You are requested to rectify the above shortcoming under the intimation to this department for further course of action.

Yours faithfully

(Atul Garg)

Director

Delhi Fire Service

dep. by

Copy to:-

The Director of Education, M.C.D, Civic Centre, Minto Road, New Delhi-110001.