



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/Business/2023/SZ/ 1601

Dated: 02/08/2023

To,

Mrs. Ruchi Sharma
Paharpur Business Centre
A Division of M.s Chemical & Metallurgical Designs Co. Limited
21-22, Nehru Place, New Delhi 110019

Sub: Regarding renewal of Fire Safety Certificate in r/o Paharpur Business Centre, A Division of M/s Chemical & Metallurgical Designs Co. Limited at 21-22, Nehru Place, New Delhi 110019
Sir,

This is in reference with your letter received in this department through Email dated 05/07/2023 on the subject cited above. The premise was inspected by the concern officer of this department on 24/07/2023 in the presence of Mr. Vikas Goyal (CA) to verify the compliance of fire prevention and fire safety measures required under the rules. Accordingly fire safety arrangement were tested / checked and found following observation.

1. Fire check doors found damage at some places.
2. First aid hose reel provided but found nonfunctional.
3. Automatic detection system provided but found nonfictional.
4. MOEFA found removed.
5. Internal hydrant provided but found nonfunctional.
6. Fire fighting pumps provided but not functional.
7. Exit Signage found removed.
8. Temperary structure at terrace level is not allowed.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours Faithfully

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to:

1. The Executive Engineer (Bldg.), MCD, Jal Vihar, Lajpat Nagar, New Delhi-110024