

C-19

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No. F6/DFS/MS/EH/WZ/2023/ 425

Dated: 01/08/2023

To,

The Joint Commissioner of Police,  
Licensing Unit, 1<sup>st</sup> floor, Police Station,  
Defence Colony, New Delhi.  
[adlcp.lic-dl@nic.in](mailto:adlcp.lic-dl@nic.in)

**Subject: Regarding issuance of NOC from fire safety point of view in respect of M/s Rion (A Unit of U and G Food Beverages Pvt. Ltd.), Located at Shop No. 167, Upper Ground Floor, Kapil Vihar, Pitampura, New Delhi – 110034.**

Sir,

Please refer to your online application no. 2023071412550 dated 14/07/2023 on the subject cited above. In this connection, it is to inform you that the premises was inspected by the officer concerned of this department on 26/07/2023 in the presence of Sh. Kartik Goyal to see the functioning of fire safety equipments provided in the building.

During inspection, it has been observed that the above restaurant is running at Upper Ground Floor in a building comprised of Basement + Stilt + Upper Ground + 03 Upper floors. Fire safety arrangements such as Fire Extinguishers, First-Aid Hose Reel, Automatic fire detection and alarming system, MOEFA, Internal Hydrant etc provided. However the following shortcomings were observed.


1. Width of staircase is 1 x 95cm & 1 x 115cm provided against requirement of 1.5m x 2.
2. Width of door size is 1 x 90cm & 1 x 100cm provided against requirement of 1.5m x 2.
3. First Aid Hose reel provided but not functional.
4. Automatic fire detection and alarming system is provided but not functional.
5. MOEFA is provided but not functional.
6. Internal hydrant is provided but not functional.
7. Terrace level pump capacity of 450 LPM is provided but not functional.
8. Overhead water storage tank capacity of 20000ltr is not provided.
9. Exit signages is not provided.

In view of above Shortcomings, the application for issuance of Fire safety Certificate is rejected. The occupancy of the Building/premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/occupier. The licensing issuing authority/statutory authority is requested that premises should not be allowed to run till it provided all necessary fire arrangements.

Yours faithfully

  
(Atul Garg)  
Director

Copy to: -

1. The Owner/Occupier, M/s Rion (A Unit of U and G Food Beverages Pvt. Ltd.), Located at Shop No. 167, Upper Ground Floor, Kapil Vihar, Pitampura, New Delhi – 110034.
  2. The DHO, MCD, Keshav Puram Zone, Public Health Department, A- Block, Keshav Puram, New Delhi.
-   
27/7/2023