



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE

No. F6/DFS/MS/WZ/2023/ 1585

Dated: 28/07/2023

To,

A.P.S. Enterprises,
C-29-30, Rajdhani Market,
Raghubir Nagar, Tagore Garden Extn.,
New Delhi - 110027.

Sub: - **Inspection report in r/o M/s. A.P.S. Enterprises, Located at C-29-30, Rajdhani Market, Raghubir Nagar, Tagore Garden Extn., New Delhi - 110027.**

Sir,

Please refer to your Email dated: - 20/06/2023 on the subject cited above. In this connection, it is to inform you that the premises was inspected by officer concerned of this department on 18/07/2023 in the presence of Sh. A.P Singh to see the functioning of fire safety equipments provided in the Building.

During inspection, It has been observed that the said building/premises is comprised of Ground floor only was issued FSC vide this department letter No. F6/DFS/MS/2020/WZ/230 dated 29/06/2020. Fire safety arrangements such as Fire Extinguishers provided. However the following shortcomings were observed: -

1. Automatic Sprinkler System is provided but not functional.
2. Main fire pump capacity of 180LPM is found removed.
3. Overhead water storage tank capacity of 5000 ltr is found removed.

In view of above, application for renewal of Fire safety Certificate is rejected. The occupancy of the Building/ premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/occupier. The licensing issuing authority/statutory authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements.

Yours faithfully


(Atul Garg)
Director

Copy To: -

1. The Executive Engineer (Building). MCD, West Zone, MCD, Rajouri Garden, New Delhi.
(Email Id: - eepwddelhim132@gmail.com)

o/c 28/07/23
27/7/23