

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001**

No. F.6/DFS/MS/School/2023/SZ/ 307

Dated: 04/08/2023

To

The Principal,
ASMS SKV at Mahipalpur,
New Delhi 110038 (School ID 1720032 & 1720029)

Sub: Regarding issuance of FSC in r/o ASMS SKV and GBSSS at Mahipalpur, New Delhi 110038
(School ID 1720032 & 1720029)

Sir,

This has reference to your Email dated 10/07/2023 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 24.07.2023 in the presence of Mr. Pushpa Mahto (Principal) to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. Fire Extinguishers found not refilled.
2. First aid hose reel provided but nonfunctional.
3. Terrace level Fire Pump capacity of 450 LPM x 2 provided but found nonfunctional.
4. Exit signage found removed at some places.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,

(ATEL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to:-

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi 110054.