

C-25

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110001

No: F.6/DFS/MS/School/2023/SZ/ 310

Dated: 07/08/2023

To,

The Principal,
Guru Harkrishan Public School,
MS Block, Hari Nagar, New Delhi-110064.

Sub: - Regarding issuance of Fire Safety Certificate in r/o Guru Harkrishan Public School, MS Block, Hari Nagar, New Delhi-110064.

Sir,

This has reference to your letter No. GHPS/HN/2485/23-24 dated 25/07/2023 on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the school on 02/08/2023 to verify the fire safety arrangements in accordance with the Rules. At the time of inspection Smt. Kulvinder Kaur (Principal) was present and it was observed that the school building is comprised of ground plus one upper floor and have following shortcomings:-

1. Corridor leading to second staircase found blocked.
2. Fire Extinguishers ABC type with ISI marked not provided.

In view of above, the fire safety certificate cannot be considered at this stage. You are requested to rectify the above shortcoming under the intimation to this department for further course of action.

Yours faithfully

(Atul Garg)

Director

Delhi Fire Service

Copy to:-

The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.