

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No: F.6/DFS/MS/School/SZ/2023/305

Dated: - 04/08/2023

To,

The Manager/Director,  
J.D. Tytler School, R-Block,  
New Rajinder Nagar, New Delhi- 110060.

Sub.:- Regarding renewal of Fire Safety Certificate in r/o J.D. Tytler School, R-Block, New Rajinder Nagar, New Delhi- 60.

Sir,

Please refer to your letter No. JDTS/letter/2023-24/108 dated 26.06.2023, on the subject cited above. In this connection, it is to inform you that the aforesaid school building have been inspected by the officers concerned of this department on 25.07.2023 in presence of Sh. J.G. Babbar, C.A.O. to check the functionability of fire safety arrangements.

During the inspection, it was also observed that the school building is comprised of basement, ground plus three upper floors. Fire safety arrangement such as fire extinguishers, hose reel, overhead water tank, exit signages etc. found provided. However following shortcomings were observed: -

1. Fire extinguisher found removed and not refill.
2. Hose reel is provided but not covered full area.
3. Fire pump capacity of 450 LPM provided but found not in auto mode.
4. Overhead water tank capacity of 15,000 lts. provided but found leaked.
5. Exit signage found not provided.

In view of the above, 'Fire Safety Certificate' cannot be renewed at this stage. You are requested to rectify the above-mentioned fire safety arrangements under intimation to this department.

Yours faithfully

(Atul Garg)  
Director  
Delhi Fire Service

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi- 110054.