

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SZ/2023/ 1621

Dated: 04/08/2023

To,

The Principal,
MBS School of planning and Architecture,
Plot No. 01, Sector – 09, Dwarka,
New Delhi – 110075.

Subject: Renewal of Fire Safety Certificate in r/o MBS School of planning and Architecture located at Plot No. 01, Sector – 09, Dwarka, New Delhi – 110075.

Sir,

Please refer to your letter No. ACME/DFS/2023, dated 15/07/2023 on the subject mentioned above. In this connection it is to inform you that the premise was re-inspected by the officer from this department on 27/07/2023 in presence of Sh. Ravish (Admin) for fire safety point of view.

During the course of inspection following shortcomings were observed.

1. Only two staircases found provided in main block however 03 staircases were seen during earlier visit.
2. Basement found closed and could not be checked.
3. Hose reel hose & hydrants found nonfunctional.
4. Terrace fire pumps found nonfunctional. The pumps must be functional in auto mode.
5. Underground fire water tank of capacity 50,000 ltr not seen during the visit.
6. Exit signage's found removed at some places.
7. Communication system in lift car found nonfunctional.
8. Dully fill form J & K are not submitted.

You are requested to comply the above mentioned shortcomings under intimation to this department.

In view of the above shortcomings Fire Safety Certificate cannot be considered at this stage.

Yours faithfully,

(Atul Garg)

Director

Delhi Fire Service

Copy to; - Directorate of Education Old Secretariat Delhi – 110054.